Certificate of Compliance

UL Underwriters Laboratories

Issued to:

XTRALIS PTY LTD

4 North Dr Virginia Park
236-262 E Boundary Rd
Bentleigh E, Vic 3165
Australia

This is to certify that representative samples of

Smoke Detectors for Special Applications

Model Descriptions: Manufacturing Locations: Australia and Malaysia
Smoke detector, air sampling type, VESDA Laser Focus.
Models VLF-250 and VLF-500.
Must be used with a UL 1481 Listed power supply.

Have been investigated by UL LLC in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

The basic standards used to investigate products in this category (with the exception of video image smoke detectors) are ANSI/UL 268 "Smoke Detectors for Fire Alarm Signaling Systems," ANSI/UL 268A, "Smoke Detectors for Duct Application" and CAN/ULC-S529-09" Smoke Detectors for Fire Alarm Systems.

Additional Information:

 The basic requirements used to investigate video image smoke detectors in this category are contained in UL Subject 268B, "Outline of Investigation for Video Image Smoke Detectors."

See UL On-line Certification Directory at www.ul.com for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: (UL) with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs