

CERTIFICATE OF CONFORMITY

1. FIRE PROTECTION EQUIPMENT

2. **Certificate No:** **FM23FPUS0022**
3. **Equipment:** **ASD 531 Aspirating Smoke Detector**
(Type Reference and Name)
4. **Name of Listing Company:** **SECURITON AG**
5. **Address of Listing Company:** **Alpenstrasse 20, CH-3052 Zollikofen, Switzerland**
6. The examination and test results are recorded in confidential report number:
3059954 dated 29th December 2017

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM 3230:2023

8. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

9. Approval Guide Listing Category:

Alarm Signal Initiating Devices, Smoke Detectors

Alarm Signal Initiating Devices, Smoke Detectors, Very Early Warning Fire Detection (VEWFD) Systems

Certificate issued by:



17 May 2023

J.E. Marquedant
VP, Manager - Electrical Systems

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 320 (Jan 23)



CERTIFICATE OF CONFORMITY

US Certificate of Conformity No: FM23FPUS0022



10. Description of Equipment:

ASD 531 Aspirating Type Smoke Detector:

Smoke detection technology	Scattered light obscuration
Sensitivity range	SSD 31 sensitivity corresponds to 0.006%/ft (0.02%/m). to 3.15%/ft (10%/m).
	The sensitivity range can be extended up to 0.002%/m via the pre-signals.
Firmware	Version 01.04.xx
Sampling pipe	Nominal 20mm I.D., 25mm O.D.
Pipe length – pipe network	Single pipe, H shape, 55 m max. 1-3 holes per branch, transport time cannot exceed 120s on FM Approved systems
Alarm Levels	4 (Alarm, pre-signal 1, 2, 3)
Special Features	For use with compatible Approved fire alarm controls providing separate circuits for power and the standard relay contacts on the terminal board of the detector or the analogue connection via a XLM 35 interface to an Approved, compatible panel.
Displays and Controls	Displays: Several LEDs on the control unit indicate the current state of the
	ASD 531. Operating, Alarm, Fault, Detector dusty/dirty.
Relay Outputs	Criteria can be programmed on a max. of 5 relays on RIM 36
Accessories	Sampling pipe design software, ASD PipeFlow Version 2.8.0
	Usable expansion modules (max. 2 units)
	· XLM 35, RIM 36
	The ASD 531 can be linked to a higher level FACP by means of potential-free change-over contacts.
	With the XLM 35, the ASD 531 can be ideally connected to the SecuriFire and Integral fire alarm systems.
	The RIM 36 enables the availability of all three pre-signal levels as well as the states “smoke sensor dirty” and “LS-Ü blockage” as relay contacts. The relays are freely configurable (on DIP switch “Relay” no. 4).
Communication protocols	Non available, requires listed panel
	A line card is used for communication between the aspirating smoke detector and a fire alarm control panel via an addressable loop

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

F 320 (Jan 23)



Page 2 of 3

CERTIFICATE OF CONFORMITY

US Certificate of Conformity No: FM23FPUS0022



Member of the FM Global Group

Coverage	FM Data sheets, local codes and standards for aspirating smoke detectors, Area of coverage per sampling hole is usually at least the same as a spot or point detector
Operating voltage range	16.4-27 VDC, 24 VDC nominal
Operating temperature range	-22°F (-20°C) to 120°F (49°C), ambient
Sampling air temperature range	0°C to 37.8°C (32°F to 100°F) tested
Humidity range	0 to 95% RH, non-condensing
Power consumption	75 - 120mA
Enclosure	Plastic (PC/ABS) Indoor use only
Model codes	<ul style="list-style-type: none">ASD 531; for 1 sampling tube, and 1 smoke sensor without smoke level indicatorASD 531China; like ASD 531 with labeling in Chinese language
Compatible fire alarm control panels (FACPs) and power sources	The detector is to be used with Approved control panels providing separate circuits for power and alarm initiating devices. Power to the detector (both primary and standby) can also be provided by an independent FM Approved power source. The required 24Vdc primary power and 24-hour standby power for detector must be obtained locally from a means suitable for NFPA 72 applications and is to be installed in the same room as the detector with the wiring in conduit and not exceeding 6 m.

11. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

12. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

13. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
17 May 2023	Original Issue. Reference 3059954CoC

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 320 (Jan 23)

